



BID BULLETIN NO. 1
April 18, 2023

**DESIGN/CONSTRUCTION/INSTALLATION OF
 RAINWATER COLLECTION SYSTEM
 PB2023-12**

Issued pursuant to Section 22.5 of the Implementing Rules and Regulations of the Republic Act 9184 to clarify and/or amend certain provisions in the Bidding Documents issued for this project, considering the issues raised and clarifications made by prospective bidders during the Prebid Conference held on April 13, 2023, likewise, respond to bidders' written queries received within the prescriptive period of filing

A. AMENDMENT

<i>No.</i>	<i>Reference</i>	<i>From</i>	<i>To</i>
1	Terms of Reference Water Tanks (specifications)	At least 12,000L (1-2,000L 304 Stainless steel tank (collection tank) and 2-5,000L 304 stainless steel tank or polyethylene tank (storage tank)) total at the back of the TAC, and at least 25,000L (1-3,000L 304 Stainless steel tank (collection tank) and 4-5,000L or 2-10,000L 304 stainless steeltank or polyethylene tank (storage tank)) in total at the side of the Extension building, and at least 2,000L additional 304 stainless tank at roof deck.	At least 12,000L (1-2,000L 304 Stainless steel tank (collection tank) and 2-5,000L 304 stainless steel tank (storage tank)) total at the back of the TAC, and at least 25,000L (1-3,000L 304 Stainless steel tank (collection tank) and 4-5,000L or 2-10,000L 304 stainless steeltank (storage tank)) in total at the side of the Extension building, and at least 2,000L additional 304 stainless tank at roof deck.



B. ADDENDUM

No.	Reference	Addendum
1	Terms of Reference	SITE VISIT The prospective bidders are required to conduct an ocular/site visit. The prospective bidders shall be given a Certificate of Site Visit after the conduct of such. The said certificate shall form part of the bid documents to be submitted during the opening of bids. To conduct the ocular/site visit, kindly email our BAC Secretariat at esantonio@pshs.edu.ph or wzamorras@pshs.edu.ph

Amendments/addendum made herein shall be considered an integral part of Bidding Documents. The bidders are required to attach this bid supplement in the Bid Documents and shall form part thereof.


ROD ALLAN A. DE LARA
Chairperson, Bids and Awards Committee